



MAURA T. HEALEY
GOVERNOR

KIMBERLEY DRISCOLL
LT. GOVERNOR

TERRANCE M. REIDY
SECRETARY

*The Commonwealth of Massachusetts
Executive Office of Public Safety and Security
Board of Fire Prevention Regulations*

P.O. Box 1025 ~ State Road

Stow, Massachusetts 01775

(978) 567-3199 Fax: (978) 567-3121



ANTHONY P. CAPUTO
CHAIRMAN

January 19, 2023

Amy Schectman
30 Wallingford Rd
Brighton, MA 02135

Board of Fire Prevention Regulations
527 CMR 12:00 Interpretation Committee
Department of Fire Services
1 State Road
Stow, MA 01775

Official use Only
Article 210.8

Question # 1: Do the provisions of NFPA 70 2020 edition with Massachusetts Amendments allow freestanding electric ranges to be hardwired?

Response: Yes

Question # 2: Is ground fault protection per article 210.8 required for a freestanding electric range that is hardwired?

Response: No

If you have any questions or need any additional information, please contact me.

Sincerely,

Anthony P. Caputo, Chairman
Board of Fire Prevention Regulations